



Safety Tips FOR HOTELS:

Do's

- Always keep the cylinder in upright position with valve on top.
- Always install the cylinder at ground level, keeping the LPG appliance at a higher level.
- Ensure there is adequate ventilation at floor level and at top level.
- Keep the area clean. Restrict entry to authorized persons only.
- Shout and raise alarm/siren in case of unsafe conditions.
- In case of leakage, stop all operations, close all isolation valves.
- In case of valve leakage from cylinder, put the safety cap and take the cylinder to an open space.
- Use D.C.P type fire extinguishers in case of fire and/or call Fire Brigade.
- Call Fire Brigade, Aegis Puregas Team, if leakage is not controlled.

Don'ts

- Don't keep the cylinder exposed to sun, rain, dust and heat.
- Don't heat the cylinder directly or indirectly.
- Don't forget to check the cylinder for any leakage from 'O' ring and valve before connecting.
- Don't forget to turn off the valve when cylinder is not in use.
- Don't keep unconnected cylinders.
- Don't keep any extra material in the LPG shed.
- Don't allow battery operated instruments, any non-flame proof electrical items inside the LPG shed.
- No smoking inside & around the LPG shed or area.
- No naked flame anywhere inside & around the LPG shed or area